



**Burlington, WA Corporate Laboratory (a)**  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
**Bellingham, WA Microbiology (b)**  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

**Portland, OR Microbiology/Chemistry (c)**  
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
**Corvallis, OR Microbiology/Chemistry (d)**  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
**Bend, OR Microbiology (e)**  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## LEAD & COPPER RULE REPORT

Client Name: **Oregon Charter Academy**  
 30485 Boones Ferry Rd, Ste 102  
 Wilsonville, OR 97070

Reference Number: **21-26612**  
 Project: **School Lead**

System Name:  
 System ID Number:  
 DWP Source Number:  
 Multiple Sources:  
 Sample Type:  
 Sample Purpose: **Investigative or Other**  
 County:

Analyst: bsp  
 Date Received: 7/19/2021  
 Report Date: 7/28/2021  
 Approved By: bj  
 Authorized by:

Thanh B Phan  
 Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
21_50961	7/14/2021	43990202-001KF - Kitchen Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50962	7/14/2021	43990202-004BF - Men's Bathroom L Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50963	7/14/2021	43990202-005BF - Men's Bathroom R Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50964	7/14/2021	43990202-002BF - Women's Bathroom L Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50965	7/14/2021	13990202-003BF - Women's Bathroom R Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50966	7/15/2021	43990101-001OT - Janitor's Closet	1030	LEAD	5.25	ppb	15	1	200.8	4072	
21_50967	7/15/2021	43990101-002BF - Bathroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50968	7/15/2021	43990101-003BF - Bathroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50969	7/15/2021	43990101-004KF - Kitchen Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50970	7/15/2021	43990101-005BF - Bathroom Faucet	1030	LEAD	2.72	ppb	15	1	200.8	4072	
21_50971	7/15/2021	43990101-006OS - Outside Spigot	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_50972	7/15/2021	43990101-007OS - Outside Spigot	1030	LEAD	26.0	ppb	15	1	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.